

Stand-by Generator program – greater than 75 KVA

Qualifications for stand-by generator program are as follows:

- May be either single phase or 3-phase
- Generator must be wired to start automatically during outages
- Quality transfer switch is needed to conduct positive transfer of power during outages/load control events
- Must have a radio control device installed by Scenic Rivers Energy Cooperative to activate transfer switch to start generator
- Verification of generator start up will be member's responsibility
- Must have demand registering meter

Participating benefits with stand-by generator program:

- Member shall qualify for Peak Alert Service rate (policy 20-11)
- During the full load control period, no load shall register on meter. This will constitute full load transfer to generator